

CHLORINE RESIDUAL RETICULATION (free)

DATE		LOCATION																				
		HERITAGE	PLUMB	MILLTHORPE	WWL	CARCOAR	MANDURAMA	LYNDHURST	TM 'H'	GRAYS HILL	CUDAL	MANILDRA	CARGO	TM 'C'	CANO WINDR A	TRAJERE	EUG (PARK)	CAR PARK (WEST)	LAW PARK (SOUTH)	NTH RESV	TM 'L' OLD RIVER PUMP HOUSE	QUANDILLA
7/01/2016	free	0.87	1.47	0.3	0.36	0.29	1.22	0.66	>2.0							Hi	Hi	1.12	1.26	1.83	1.31	1.49
	total	1.11	1.99	0.58	0.58	0.58	1.45	0.81	>2.0							Hi	Hi	1.47	1.73	Hi	1.47	0.94
	PH	7.24	7.22	7.41	7.34	7.6	7.4	7.6	7.4													
	Turbidity	0.19	0.18	0.19	0.19	0.2	0.23	0.19	0.25													
	colour	0	0	0	0	0	0	0	0													
14/01/2016	free	1.23	>2.0	0.36	0.5	0.28	0.39	0.61	>2.0	1.28	0.81	0.85	0.3	1.39	0.91	Hi	1.45	0.78	0.69	1.69		0.93
	total	1.67	>2.0	0.48	0.72	0.37	0.58	0.83	>2.0	1.41	0.97	1.01	0.49	1.66	1.18	Hi	Hi	0.96	0.77	1.94		1.19
	PH	7.15	7.15	7.44	7.34	7.8	7.6	7.8	7.5													
	Turbidity	0.2	0.17	0.23	0.14	0.21	0.21	0.2	0.22													
	colour	0	0	0	0	0	0	0	0													
21/01/2016	free	1.14	1.62	0.46	0.7	0.26	0.69	0.46	>2.0	1.29	1.02	1	0.69	1.35	0.98	Hi	0.53	1.35	1.38	1.5	0.08	1.19
	total	1.44	1.87	0.72	0.96	0.39	1.16	0.66	>2.0	1.57	1.29	1.2	0.97	1.79	1.21	Hi	0.98	1.57	1.57	1.69	0.05	0.93
	PH	7.2	7.16	7.17	7.19	7.5	7.2	7.3	7.3													
	Turbidity	0.19	0.16	0.19	0.2	0.21	0.24	0.19	0.18													
	colour	0	0	0	0	0	0	0	0													
28/01/2016	free	1.16	1.56	0.32	0.43	0.28	0.39	0.39	>2.0	Hi	1.76	1.82	0.73	1.79	1.61	0.81	0.76	1.05	0.48	1.61	1.23	1.01
	total	1.45	1.9	0.44	0.78	0.38	0.58	0.57	>2.0	Hi	1.98	Hi	0.93	Hi	1.81	0.98	0.93	1.37	0.71	1.89	1.52	1.2
	PH	7.26	7.07	7.25	7.23	7.4	7.7	7.5	7.3													
	Turbidity	0.22	0.24	0.21	0.26	0.21	0.25	0.27	0.24													
	colour	0	0	0	0	0	0	0	0													
4/02/2016	free	1.1	1.35	0.25	0.42	0.31	0.26	0.41	>2.0	1.82	1.61	1.7	0.06	1.91	1.77	0.03	Low	1.06	0.42	0.59	1.16	1.26
	total	1.3	1.72	0.45	0.65	0.54	0.5	0.58	>2.0	1.99	1.82	1.86	0.23	Hi	1.93	Low	0.09	1.21	0.67	0.9	Hi	1.55
	PH	7.11	7.05	7.15	7.19	7.5	7.6	7.3	7.3													
	Turbidity	0.21	0.15	0.28	0.17	0.26	0.25	0.22	0.16													
	colour	0	0	0	0	0	0	0	0													
11/02/2016	free	0.78	1	0.36	0.6	0.41	0.34	0.64	>2.0	1.29	1.02	1	0.09	1.35	0.98	Hi	Hi	0.47	0.78	0.84	1.89	1.37
	total	1.05	1.24	0.51	0.9	0.59	0.54	1	>2.0	1.57	1.29	1.2	0.27	1.79	1.21	Hi	Hi	1.01	1.17	1.23	Hi	1.4
	PH	7.34	7.27	7.49	7.27	7.6	7.6	7.5	7.3													
	Turbidity	0.24	0.29	0.19	0.27	0.25	0.24	0.16	0.17													
	colour	0	0	0	0	0	0	0	0													
18/02/2016	free	1.31	1.92	0.35	0.47	0.32	0.3	1.17	>2.0	1.37	0.78	0.22	0.15	1.72	1.31	Hi		1.12	0.95	1.41	1.34	1.4
	total	1.75	>2.0	0.74	1.02	0.4	0.52	1.43	>2.0	1.88	1.13	0.35	0.34	1.84	1.66	Hi		0.92	1.2	1.56	1.67	1.51
	PH	7.24	7.18	7.27	7.32	7.4	7.3	7.5	7.5													
	Turbidity	0.26	0.27	0.23	0.18	0.3	0.24	0.22	0.19													
	colour	0	0	0	0	0	0	0	0													
25/02/2016	free	0.97	1.16	0.77	1.04	0.27	0.34	0.21	>2.0	0.85	0.58	Low	0.05		1.04	Hi	Hi	0.55	0.5	1.26	1.46	0.9
	total	1.27	1.41	1.04	1.31	0.48	0.61	0.44	>2.0	1.22	0.9	0.22	0.19		1.5	Hi	Hi	0.61	0.71	1.43	1.72	1.06
	PH	7.16	7.22	7.19	7.17	7.8	7.4	7.7	7.6													
	Turbidity	0.17	0.2	0.24	0.16	0.41	0.23	0.18	0.29													
	colour	0	0	0	0	0	0	0	0													
3/03/2016	free	1.03	1.57	0.29	0.48	0.33	0.33	0.3	>2.0	0.3	0.08	0.18	Low	0.61	0.25	Hi	1.75	0.89	Hi	1.21	1.53	Low
	total	1.42	1.84	0.54	0.72	0.53	0.62	0.53	>2.0	0.39	0.4	0.58	Low	1.03	0.45	Hi	Hi	1.01	Hi	1.38	1.61	0.04
	PH	7.36	7.23	7.41	7.36	7.6	7.4	7.6	7.5													
	Turbidity	0.31	0.22	0.21	0.32	0.27	0.26	0.22	0.28													
	colour	0	0	0	0	0	0	0	0													
10/03/2016	free	0.81	1.24	0.46	0.47	0.28	0.28	0.39	>2.0	0.86	0.65	0.68	0.53	1.06	0.83	Low	Low	0.94	0.99	0.79	Low	0.71
	total	1.07	1.51	0.71	0.66	0.52	0.73	0.68	>2.0	1.05	0.89	0.94	0.71	1.25	0.99	Low	Low	0.99	1.34	0.85	Low	0.82
	PH	7.19	7.22	7.34	7.29	7.4	7.6	7.5	7.4													
	Turbidity	0.22	0.16	0.2	0.17	0.32	0.29	0.2	0.37													
	colour	0	0	0	0	0	0	0	0													
17/03/2016	free	0.71	1.03	0.21	0.47	0.26	0.69	0.27	>2.0	1.5	1.31	1.36	0.51	0.92	0.64	Hi	Hi	0.78	0.7	0.91	0.32	0.57
	total	0.96	1.18	0.92	0.96	0.57	1.11	0.86	>2.0	1.66	1.5	1.55	0.7	1.13	0.89	Hi	Hi	1	1.1	1.19	0.48	0.58
	PH	7.22	7.04	7.35	7.44	7.3	7.5	7.4	7.4													
	Turbidity	0.18	0.22	0.22	0.17	0.25	0.19	0.17	0.22													
	colour	0	0	0	0	0	0	0	0													
24/03/2016	free	1.2	1.66	0.46	0.53	0.58	0.48	0.22	>2.0	1.43	1.29	1.3	0.53	0.9	0.68	Hi	Hi	1.01	1.09	1.79	1.04	1.3

